



For the scope of validity cULus:

- Rated operating voltage ≤ 32 V PELV
- Rated operating current for each connection ≤ 3 A
- Enclosure type 1
- For use in NFPA 79 applications only.
- The device shall be connected only by using any R/C (AVLV2/AVLV8) AS-i flat cable, style 2103 with TPE or style 20549 with PUR insulation, for field connection in respect of the Conditions of Acceptability, having suitable ratings.

Für den Gültigkeitsbereich cULus:

- Bemessungsbetriebsspannung ≤ 32 V PELV
- Bemessungsbetriebsstrom pro Anschluss ≤ 3 A
- Enclosure type 1
- Nur für die Benutzung im Anwendungsbereich der NFPA 79.
- Für den Anschluss des Gerätes darf nur ein R/C (AVLV2/AVLV8) AS-i-Flachkabel, Style 2103 mit TPE- oder Style 20549 mit PUR-Isolation für „field Connection“ gemäß der „Condition of Acceptability“ mit geeigneten Daten verwendet werden.

Dans le champ d'application cULus :

- Tension d'alimentation assignée ≤ 32 V TBTP
- Courant d'alimentation assigné par raccord ≤ 3 A
- Enclosure type 1
- Seulement pour l'emploi dans le champ d'application de la NFPA 79.
- Pour le raccordement de l'appareil, un câble plat AS-i R/C (AVLV2/AVLV8), style 2103 avec isolation TPE ou style 20549 avec isolation PUR pour „field connection“ selon les „Conditions of Acceptability“ et ayant des données appropriées, doit être utilisé.



ifm electronic gmbh • Friedrichstr. 1 • D 45128 Essen
<https://www.ifm.com> • e-mail: info@ifm.com